



R&D Services, Inc.
102 Mill Drive
Cookeville, TN 38501
(931) 372-8871
www.rdservices.com

PRODUCT LISTING

RDS-LF9990

Issued: March 16, 2020
Renewal Due: January 1, 2021

-
- | | |
|-------------------------------------|--|
| 1.0 PRODUCT: | PF Premium |
| 2.0 MANUFACTURER: | Prairie Fibre Inc. |
| 3.0 MANUFACTURING LOCATIONS: | 280 Park Road West
Steinbach, MB Canada |
| 4.0 PRODUCT TYPE: | Loose-Fill Cellulose Insulation |
-

5.0 PRODUCTS ARE EVALUATED ACCORDING TO THE FOLLOWING STANDARD:

- 5.1 CAN/ULC-S703-09 (2015) "Standard for Cellulose Fibre Insulation for Buildings"

6.0 IDENTIFICATION AND MARKINGS:

- 6.1 Packaging of the listed product is permitted by R&D Services, Inc. to use the (RDS) listing logo (containing the listing number), and the RDS ISO-17025 accreditation identification (TL-566).

7.0 DESCRIPTION OF LISTING PROGRAM:

- 7.1 Bi-annual on-site inspections of procedures and product testing are performed by RDS through unannounced visits to the facility. During each inspection the following actions are taken:
- 7.1.1 Samples of cellulose product are selected for testing referenced in 7.2, 7.3, and 7.4.
 - 7.1.2 In-house quality control records are reviewed for frequency and consistency
 - 7.1.3 Quality control test equipment is checked for calibration and functionality
- In addition to bi-annual inspections, the manufacturer submits additional product for testing on a bi-annual basis.
- 7.2 Each quarter, RDS conducts the following tests:
- 7.2.1 Limiting Design density (Type 1 Open Spaces) - CAN/ULC S703-09, Section 6.3.3
 - 7.2.2 Open Flammability - CAN/ULC S703-09, Section 6.3.9
 - 7.2.3 Smoulder Resistance - CAN/ULC S703-09, Section 6.3.12
- 7.3 Bi-annually, RDS conducts the following tests:
- 7.3.1 Thermal Transmission Properties - CAN/ULC S703-09, Section 6.3.13
- 7.4 Annually, RDS conducts the following tests:
- 7.4.1 Corrosiveness – CAN/ULC S703-09, Section 6.3.2
 - 7.4.2 Fungi Resistance – CAN/ULC S703-09, Section 6.3.7
 - 7.4.3 Moisture Vapour Sorption – CAN/ULC S703-09, Section 6.3.8
 - 7.4.4 Open Flammability Permanency - CAN/ULC S703-09, Section 6.3.10
 - 7.4.5 Separation of Chemicals – CAN/ULC S703-09, Section 6.3.11

8.0 INSTALLATION:

- 8.1 Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.



R&D Services, Inc.
 102 Mill Drive
 Cookeville, TN 38501
 (931) 372-8871
 www.rdservices.com

PRODUCT LISTING

RDS-LF9990

Issued: March 16, 2020
 Renewal Due: January 1, 2021

9.0 EVALUATED PROPERTIES AND RESULTS:

- 9.1 The table shows the performance requirements of CAN/ULC-S703-09 (2015). The evaluated product meets or exceeds the values in the table.
- 9.2 The limiting design density and thermal transmission properties are actual product performance values.

PROPERTY	RESULT
Limiting Design density (lb/ft ³)	1.47
(kg/m ³)	23.55
Open Flammability (W/cm ²)	GREATER THAN 0.12
Open Flammability Permanency (W/cm ²)	GREATER THAN 0.12
Smoulder Resistance (max %)	LESS THAN 15
Corrosiveness (all metals)	PASS
Moisture vapour sorption (%)	LESS THAN 20
Thermal Transmission Properties (°F·ft·h/Btu·in.)	3.60
(m·K)/W	25.0
Fungi resistance	NO GROWTH
Separation of Chemicals (%)	LESS THAN 1.5

This listing report indicates that R&D Services, Inc. has evaluated this product as described herein, and it is eligible for listing. No other product is covered by this listing. R&D Services, Inc. makes no warranty, expressed or implied, or guarantee regarding the product covered by this listing.